

ACCURATE ANALYTIC ★ ACCURATE ANALYTIC ★ ACCURATE ANALYTIC ★ ACCURATE ANALYTIC ★ ACCURATE ANALYTIC ★

Kerala State Pollution C Board PCB/CL/RL/54/2021 - 'A' Grade

ACCURATE ANALYTIC
(General Purpose Laboratory)

TEST REPORT

Issued to
M/s. ST.RITA'S PUBLIC SCHOOL
Palluruthy P.O
MLA Road, Kochi-682006

Sample No : 2112/2025
Report No : 2409/2025
ULR-TC949625000000231F

REPORT DATE : 07.02.2025

SAMPLE SUBMITTED BY CUSTOMER

- Sample Identified as : Drinking Water
- Sampling Method : NA
- Sample Condition : Fit for analysis
- Sample Quantity : 1 Litre sample in Plastic Bottle & 250ml in Sterile bottle
- Client Application Date : 05.02.2025
- Marks, if any : NIL
- Sample Description : Clear liquid

Sample Recd : 05.02.2025 Test Start Date : 05.02.2025 Test End Date : 07.02.2025

RESULT OF ANALYSIS

S.No	PARAMETERS	PROTOCOL	RESULT	UNIT	Limit as per IS 10500:2012 RA 2018
1	Colour	IS 3025 Part 4 : 2021	<1	Hazen Unit	5
2	Odour	IS 3025 Part 5 : 2018	Agreeable	—	Agreeable
3	Taste	IS 3025 Part 7 : 2017	Agreeable	—	Agreeable
4	Turbidity	IS 3025 Part 10	BDL(DL-1)	NTU	1 NTU
5	pH @ 25°C	IS 3025 Part 11 : 2022	6.95	—	6.5 to 8.5
6	Total dissolved solids	IS 3025 Part 16	46	mg/L	NMT 500
7	Calcium as Ca	IS 3025 Part 40 : 1991 RA 2019	5.18	mg/L	NMT 75
8	Chloride as Cl	IS 3025 Part 32 : 1988 RA 2019	18.88	mg/L	NMT 250
9	Total Iron as Fe	IS 3025 Part 53	0.35	mg/L	NMT 1
10	Magnesium as Mg	IS 3025 Part 46	2.36	mg/L	NMT 30
11	Sulphate as SO ₄	IS 3025 Part 24 : SEC 1 2022	BDL(DL-1)	mg/L	NMT 200
12	Total alkalinity as CaCO ₃	IS 3025 Part 23	22.88	mg/L	NMT 200
13	Total hardness as CaCO ₃	IS 3025 Part 21: 2009 RA 2019	22.68	mg/L	NMT 200

Page 1/2

Verified *[Signature]* Principal
St. Rita's Public School
Palluruthy, Cochin-682 006

ACCURATE ANALYTIC
Kochi 682006
THOPPUMPADY

Manager
St. Rita's Public School
Palluruthy, Cochin-682006

Authorised Signatory

DR. VETRI A
QUALITY MANAGER

Terms & Conditions
The test relate only to the items tested. The test report shall not be reproduced except in full, without written approval of the laboratory.
Nikarhil Road, Thoppumpady, Cochin - 682 005 Ph : 7736456830, Mob : 9249293998, Fax : 0484 2237848
Email : accurateanalytic@yahoo.co.in

ACCURATE ANALYTIC ★ ACCURATE ANALYTIC ★ ACCURATE ANALYTIC ★ ACCURATE ANALYTIC ★ ACCURATE ANALYTIC ★

Kerala State Pollution C Board PCB/CL/RL/54/2021 - 'A' Grade

ACCURATE ANALYTIC
(General Purpose Laboratory)

TEST REPORT

Report No : 2409/2025
ULR-TC949625000000231F

REPORT DATE : 07.02.2025

Sample Recd : 05.02.2025 Test Start Date : 05.02.2025 Test End Date : 07.02.2025

RESULT OF ANALYSIS

S.No	PARAMETERS	PROTOCOL	RESULT	UNIT	Limit as per IS 10500:2012 RA 2018
MICROBIOLOGY ANALYSIS					
1	E.coli	IS 15185 : 2016 RA 2021	Absent	per 100ml	Shall not be detectable
2	Coliforms	IS 15185 : 2016 RA 2021	Absent	per 100ml	Shall not be detectable

NMT-Not more than/BDL-Below Detection Limit/DL-Detection Limit

Page 2/2

>>>End of report<<<

Verified *[Signature]* Principal
St. Rita's Public School
Palluruthy, Cochin-682 006

ACCURATE ANALYTIC
Kochi 682006
THOPPUMPADY

Manager
St. Rita's Public School
Palluruthy, Cochin-682006

Authorised Signatory

KEERTHANA P.S
MICROBIOLOGIST

Terms & Conditions
The test relate only to the items tested. The test report shall not be reproduced except in full, without written approval of the laboratory.
Nikarhil Road, Thoppumpady, Cochin - 682 005 Ph : 7736456830, Mob : 9249293998, Fax : 0484 2237848
Email : accurateanalytic@yahoo.co.in

കൊച്ചി നഗരസഭ

Kochi Municipal Corporation
ഫിസ്റ്റ് ഫോഡ്: 682011
GSTIN:32AAALC1079K2ZB
ഫോൺ നമ്പർ : 0484-2369007
<https://kochicorporation.lsgkerala.gov.in>,
kochicorpsecretary@gmail.com

നമ്പർ: 329007-2025 തീയതി: 24-06-2025

sanitary certificate

It is certified that an inspection team headed by Senior public health inspector from health circle -10, Kochi Municipal Corporation inspected ST.RITAS PUBLIC SCHOOL (SECONDARY) Affiliated to CBSE No 931097 19/624 ST,augustin,s convent road Palluruthy P O .682006 on 10/4/2025 and found that ST.RITAS PUBLIC SCHOOL ,palluruthy-682006 has safe drinking water facilities for students and members of staff of the institution and maintaining the hygienic sanitation condition in the school building and the campus as per the norms prescribed by central/state GOVT at the time of inspectionThe above certificate is valid for a period of one year

CLEAN CITY MANAGER

TO

THE PRINCIPAL

ST.RITAS PUBLIC SCHOOL PALLURUTHY

For *[Signature]* DEEPA V
SENIOR PUBLIC HEALTH INSPECTOR GRA I
PALLURUTHY ZONAL OFFICE C-8
KOCHI MUNICIPAL CORPORATION

[Signature] Principal
St. Rita's Public School
Palluruthy, Cochin-682 006

[Signature] Manager
St. Rita's Public School
Palluruthy, Cochin-682006